

LICENCE

No. 18309

Issued to:
Applicant:
THOREM bvba
Meensesteenweg 161
8501 BISSEGEM
Belgium

Licensee:
THOREM bvba
Meensesteenweg 161
8501 BISSEGEM
Belgium



Product : conduit systems for cable management
Trade name(s) : PECHEL
Type(s)/model(s) : Conduits M16, M20, M25 , M32 , M40, M50

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1493


SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 11/04/2013


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	conduit systems for cable management
Trade name(s)	:	PECHEL
Type(s)/Model(s)	:	Conduits M16, M20, M25 , M32 , M40, M50
type of conduit (1)	:	rigid conduits, non-metallic
type of conduit (2)	:	classification 3-2-3-1
type of conduit (3)	:	plain
method of connection	:	non-threadable
resistance to compression	:	medium
resistance to impact	:	light
lower temperature range	:	-15°C
upper maximum temperature range	:	+60°C
electrical characteristics	:	with electrical insulating
resistance to flame propagation	:	non-flame propagating
colour(s)	:	grey RAL 7035 & RAL 7037

TESTS

Test requirements

NBN EN 61386-1 based on EN 61386-1:2008
NBN EN 61386-21 based on EN 61386-21:2004 + A11:2011

Test results

The test results are laid down in certification firl ref. 594143/01

Remarks

This certificate is based on test report ref. 594143.01


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 11/04/2013

Department Manager,
Product Certification :

Certification Manager :

 2013-04-11

FACTORY LOCATION(S)

THOREM bvba
Meensesteenweg 161
8501 BISSEGEM
Belgium